

**Certificate Number:** AZ 69026050

Page: 0001



## CERTIFICATE OF SUITABILITY

Authorised marking: TUV-026050-E

TÜV Rheinland Australia Pty Ltd "Electrical Product Safety Certification (EPSC) Scheme", accredited by JAS-ANZ in accordance with ISO/IEC 17065, has issued this certificate under JAS-ANZ accreditation. The electrical equipment described hereunder has been evaluated and found to be electrically safe at the time of certification and met the minimum safety requirements contained in Australian Standard AS/NZS 3820 as of current. It is a requirement that all equipment supplied under this certificate shall be identical to the equipment as certified. The certificate holder may affix the above mentioned authorised marking on the product.

### CERTIFICATE HOLDER:

Sunsynk Australia Pty Ltd  
230 Morrison Road, Midvale,  
Perth WA6056  
Australia

### DESCRIPTION OF EQUIPMENT

**Declared class:**

Non-declared

**Product:**

Hybrid Inverter

**Trade Name / Manufacturer:**

SUNSYNK

**Model Number:**

SUNSYNK-3K-SG04LP1 ; SUNSYNK-3K-SG04LP1-24 ;  
SUNSYNK-3.6K-SG04LP1 ; SUNSYNK-5K-SG04LP1 ;  
SUNSYNK-6K-SG04LP1

**Ratings:**

Ratings refer to CONTINUATION SHEET 1-2 for details

**Standard:**

AS/NZS 4777.2:2020+A1  
IEC 62109-1:2010  
IEC 62109-2:2011

**Issue Date:**

13/05/2022

**Expiry Date:**

13/05/2027

*Signed for and on behalf of TÜV Rheinland Australia Pty Ltd*

A handwritten signature in blue ink, appearing to read 'Grant Li', positioned above a horizontal line.

Grant Li



Acc. No. Z2870404AA  
[www.jas-anz.org/register](http://www.jas-anz.org/register)

**Certificate Number:** AZ 69026050

Page: 0002



## CERTIFICATE OF SUITABILITY

Authorised marking: TUV-026050-E

CONTINUATION SHEET 1

DESCRIPTION OF EQUIPMENT

Ratings:

For all models: SUNSYNK-3K-SG04LP1, SUNSYNK-3K-SG04LP1-24,  
SUNSYNK-3.6K-SG04LP1, SUNSYNK-5K-SG04LP1, SUNSYNK-6K-SG04LP1

Protection: Class I, IP65, PD 2 Internal; PD 3 External

Operating Temp.: -45°C to 60°C (>45°C derating)

Overvoltage Category (OVC): Battery and PV sides: II;

Grid side: III

PV input:

Vmax: 500Vdc

VMPP : 150 - 425Vdc

Isc: 17; 17; 17+17; 17+17; 17+17A

I<sub>max</sub>: 13; 13; 13+13; 13+13; 13+13A

Battery input:

Type: Lead-acid or Li-ion

Voltage range: 40-60; 20-30; 40-60; 40-60; 40-60Vdc

Max charging current: 70; 140; 90; 120; 135A

Max discharging current: 70; 140; 90; 120; 135A

Issue Date: 13/05/2022

Expiry Date: 13/05/2027

*Signed for and on behalf of TÜV Rheinland Australia Pty Ltd*

A handwritten signature in blue ink, appearing to read 'Grant Li', positioned above a horizontal line.

Grant Li



Acc. No. Z2870404AA  
[www.jas-anz.org/register](http://www.jas-anz.org/register)

**Certificate Number:** AZ 69026050

Page: 0003



## CERTIFICATE OF SUITABILITY

Authorised marking: TUV-026050-E

CONTINUATION SHEET 2

DESCRIPTION OF EQUIPMENT

Ratings:

AC output:

Rated Output voltage: L/N/PE,230/240

Rated frequency: 50Hz,

Max/ Rated Output Apparent power: 3kVA; 3kVA; 3.6kVA; 5kVA;  
6kVA

Max / rated Output Power: 3kW; 3kW; 3.6kW; 5kW; 6kW

Max / Rated Output current: 13A; 13A; 15.7A; 21.7A; 26.1A

Power factor: 0.8 leading to 0.8 lagging

Stand Alone:

Rated Output voltage: L/N/PE,230/240

Rated frequency: 50Hz,

Max / Rated Output Apparent power: 3; 3; 3.6; 5; 6kVA

Max / Rated Output current: 13; 13; 15.7; 21.7; 26.1A

Issue Date: 13/05/2022

Expiry Date: 13/05/2027

*Signed for and on behalf of TÜV Rheinland Australia Pty Ltd*

A handwritten signature in blue ink, appearing to read 'Grant Li', positioned above a horizontal line.

Grant Li



Acc. No. Z2870404AA  
[www.jas-anz.org/register](http://www.jas-anz.org/register)